

## SECTION 26 33 01

### DC BATTERY SYSTEM

#### PART 1- GENERAL

##### 1.01 SECTION INCLUDES:

- A. Batteries.
- B. Battery Rectifier/Chargers.
- C. Disconnect switch and circuit breaker.
- D. DC Distribution panel.

##### 1.02 MEASUREMENT AND PAYMENT:

- A. General: DC battery system, as specified herein, will not be measured separately for payment but will be paid for as part of the Contract lump-sum price for the related electrical or electronic systems work as indicated in the Bid Schedule of the Bid Form.

##### 1.03 REFERENCES:

- A. American National Standards Institute (ANSI)
  - 1. Z358.1 Emergency Eye Wash and Shower equipment
- B. American Society for Testing and Materials (ASTM)
  - 1. ASTM B187 Standard Specifications for Copper stock
- C. California Code of Regulations
  - 1. Title 24, Part 2 California Building Code
  - 2. Title 24, Part 3 California Electrical Code
  - 3. Title 24, Part 9 California Fire Code
- D. Code of Federal Regulations (CFR)
  - 1. Title 40 – Protection of Environment
    - a. Part 261.3 Identification and Listing of Hazardous Waste
    - b. Part 273.1 Standards for Universal Waste Management
  - 2. Title 49 – Transportation of Hazardous Material
    - a. Part 105 Hazardous Materials Program Definitions and General Procedures.

## DC BATTERY SYSTEM

- E. Institute of Electrical and Electronics Engineers (IEEE)
1. 450 IEEE Recommended Practice for Maintenance Testing, and Replacement of Ventilated Lead-Acid Batteries for Stationary Applications.
  2. 484 IEEE Recommended Practice for Installation Design and Implementation of Vented Lead-Acid Batteries for Stationary Applications
  3. 485 IEEE Recommended Practice for Sizing Lead Acid Batteries for Stationary applications.
  4. 1184 IEEE Guide for Batteries for Uninterruptible Power Systems.
  5. 1187 IEEE Recommended Practice for Installation Design and Installation of Valve-Regulated Lead-Acid (VRLA) Batteries for Stationary Applications.
  6. 1188 IEEE Recommended Practice for Maintenance, Testing, and Replacement of VRLA Batteries for Stationary Applications.
  7. 1189 IEEE Guide for Selection of VRLA Batteries for Stationary Applications.
  8. 1375 IEEE Guide for Protection of Stationary Battery Systems.
  9. 1491 IEEE Guide for Selection and Use of Battery Monitoring Equipment in Stationary Applications.
- F. National Electric Manufacturing Agency (NEMA)
1. 250 Enclosure for Electrical Equipment (600 Volts)
  2. AB1 Molded Case Circuit Breakers
  3. PB 1 Panel Boards
  4. PB 1.1 Instructions for installations and Maintenance of Panel Boards
- G. National Fire Protection Association (NFPA)
1. 70 National Electrical Code
  2. 1 Uniform Fire Code (UFC)
- H. Underwriters Laboratories (UL)
1. UL 67-88 Standards for safety Panelboards
  2. UL 1989 Standby Batteries

## DC BATTERY SYSTEM

### 1.04 SUBMITTALS:

Submit the followings:

- A. Manufacturer's product description, catalog data and information.
- B. Manufacturer's arrangement, wiring and detail drawing.
- C. Power consumption calculations. Estimated average power and peak power demand shall be provided.
- D. Battery and battery charger sizing calculations.
- E. Product data and catalog cuts for battery, battery chargers and disconnect switches.
- F. Available short circuit current, maximum continuous current and maximum voltage ratings of the battery system.
- G. The voltage, current and fault current interrupting ratings of the protective devices rated for use in a DC circuit.
- H. Certificates:
  - 1. Factory trained manufacturer's representative(s) shall certify in writing that the equipment has been installed, adjusted and tested in accordance with the manufacturer's recommendations. The contractor shall provide three (3) copies of manufacturer's representative's certification.
- I. Supplier Qualifications:
  - 1. The manufacture of the batteries and battery charger must have a minimum of five (5) years of manufacturing experience.
  - 2. Battery and battery chargers shall be proven standard products, or equivalent to the standard products of manufacturer's engaged in the production of such equipment for at least the past five (5) years.

### 1.05 QUALITY ASSURANCE:

Battery and charger components, devices and accessories shall be listed and labeled as defined in NFPA 70. The system and component shall conform to IEEE 485, IEEE 1184, NEMA 250, AB1, PB1 and UL 67-88. Batteries shall be new and manufactured no more than six months prior to installation.

### 1.06 DELIVERY, STORAGE AND HANDLING:

- A. Batteries shall be delivered in secured moisture proof package and per manufacture's shipping requirements.

## DC BATTERY SYSTEM

- B. Equipment shall be handled and stored in conformance with manufacturer's instructions. One copy of these instructions shall be included with the equipment at the time of shipment.

### 1.07 PROJECT / SITE CONDITIONS:

- A. The batteries and battery charger shall be suitable for the operation under the following conditions:

Ambient Temperature Ranges:

1. Minimum temperature -7°C
2. Maximum daily temperature +40°C
3. Maximum daily average temperature +30°C

### 1.08 WARRANTY:

- A. A warranty for the batteries and the battery charger shall be provided and signed by the manufacturer and installer agreeing to correct the deficiencies and replace components fail in materials or workmanship.
- B. Batteries shall have warranty of one (1) year from the date of the battery is placed in service and additional warranty of nine (9) years, pro rata, to deliver not less than 90% of its rated capacity.

## PART 2-PRODUCTS:

### 2.01 SYSTEM REQUIREMENTS:

- A. General:
  1. The battery systems shall include a primary input circuit breaker, isolation transformer, batteries, battery charger, dc filter, battery racks, disconnect switch, dc distribution panel, and related accessories as specified herein.
  2. For UPS Battery System see section 26 34 37 for Battery Rectifier/Charger specifications.
  3. Blocking diodes of sufficient voltage and current rating shall be used to isolate the main DC Bus from the battery string.
  4. Battery racks shall be designed for the seismic zone in accordance with applicable requirements of the California Building Code and the California Electrical Code.
  5. Battery system shall be installed in a ventilated room. A forced air ventilation system composed of fan, ducting and a hood properly sized, shall be provided to remove all potentially hazardous gases from the battery racks and vent it directly to the outlet.

## DC BATTERY SYSTEM

6. Provide the air flow sensors and associated electronics and monitoring circuits which will provide local alarming and remote alarming to Operation Control Center (OCC) via Supervisory Control And Data Acquisition (SCADA).
7. Battery system shall be sized to provide additional 20% capacity over the calculated equipment power.
8. The battery system shall be installed for ease of maintainability. All interface cables and accessories for batteries and battery cabinets shall be provided for installation as a complete system. If slide tray is used, each battery slide tray shall be automatically disabled from the system when slide tray is pulled for service.

### B. MANUFACTURERS:

All components of each system shall be supplied by one manufacturer. Battery component shall be manufactured by following:

1. Eastpenn
2. C and D Power System
3. Yuasa-Exide Power Inc
4. Or Approved Equal

### C. BATTERIES:

1. The batteries shall be of heavy-duty, sealed, and maintenance-free design with solid copper, lead-plated posts in individual cells. The batteries shall have the following:
  - a. The battery cells shall be sealed valve regulated lead acid type (Gel or AGM (Absorbent Glass Mat)) with a minimum of ten (10) years of life under normal usage.
  - b. The battery consists of individual cells in molded, flame-retardant, durable and impact resistant cases.
  - c. The battery cell posts shall be bolted with lead plated copper bars using stainless steel hex-head nuts.
  - d. The battery cells warranted free from defects in materials and workmanship for five years.
  - e. The batteries shall consist of sufficient number of cells to provide nominal floating voltage as specified in the Contract.
  - f. The battery capacity shall be sized in accordance with IEEE 485. Contractor shall establish the required capacity in rated ampere-hours (as specified for that location) discharge rate to 1.75 V per cell at 77°F.
  - g. No venting of any gas under normal operation.

## DC BATTERY SYSTEM

- h. The battery cells shall be equipped with self-resealing flame arresting safety vents.

### D. RATINGS:

1. The battery voltage rating shall be as indicated with a tolerance of plus 16 percent or minus 12 percent. Battery shall have ampere-hour capacity to provide rated power to all connected equipment and devices for as specified hours.
2. The battery shall be able to retain full capacity during long term float service without maintenance.
3. The battery shall be sized to provide full operation as specified in the Contract at 50°C ambient without charger.
4. Complete battery system dimensions as specified in the Contract.
5. The battery shall be able to start up after AC supply failure. The line breaker must be closed before charger voltage is restored.

### E. CELL CONTAINMENT:

1. The individual cell housing shall be heat-resistant and shall not deteriorate or become cloudy upon exposure to the electrolyte.
2. The covers shall be cemented in place to provide a permanent leak-proof seal.
  3. Cell terminal posts shall be clearly and permanently identified.

### F. NAME PLATE:

1. Each battery shall be legibly and permanently marked with the following:
  - a. Manufacturer's name
  - b. Battery and cell type
  - c. One-minute, one-hour, and eight-hour ampere ratings
  - d. Month and year of manufacture
  - e. Ampere-hour capacity for as specified hours

### G. ACCESSORIES:

1. Any manufacturer's special tools for removal and replacement of batteries shall be provided.
2. Each battery slot shall have identification number for its position in the string.
3. Battery log-book.

## DC BATTERY SYSTEM

4. One (1) rack mounted thermometer for battery ambient temperature.
5. Each battery module shall have identification label for each corresponding location and date of installation.

### H. BATTERY CHARGER:

1. Battery chargers shall be fully regulated with power semiconductor devices, convection-cooled, constant-voltage type complying with NEMA PE 5. The charger shall be rated for operation in the voltage level and number of phases as indicated in the Contract Drawings.
2. Battery charger enclosure shall be NEMA 250, Type 1. Enclosure shall be provided with a hinged front panel complete with lockable handle and two point latches, minimum.
3. Battery charger shall be rated as follows:
  - a. Capacity In accordance with its associated battery size and continuous DC load
  - b. Recharging Shall be able to recharge the fully discharge battery capacity as soon as safely possible without compromising the battery life. The rate of charging current to the battery module shall be such that it will not overheat the batteries and consistent with battery manufacture's specifications for its safe operation.
  - c. Output current In accordance with its battery size and continuous DC load.
  - d. Regulation  $\pm 1\%$  of output DC voltage over its complete load range with  $\pm 10\%$  variation of input AC voltage.
  - e. Current limiting Adjustable from 90 to 115%, factory set at 110% of output normal current rating.
4. The charger, in addition to charging the battery, shall carry the continuous load, while the battery supplies all of the heavy, non-continuous current demands
5. The battery chargers shall be equipped with the following features:
  - a. One DC voltmeter (voltage as specified in the contract)
  - b. One DC ammeter, range as applicable
  - c. One AC input pilot light marked AC POWER ON.

## DC BATTERY SYSTEM

- d. Float-equalize switch
- e. Float and equalizing voltage adjusting potentiometer
- f. Two ground detection alarm relays, positive and negative, for local and remote supervisory annunciation.
- g. AC input molded case circuit breaker, NEMA AB1
- h. DC output molded case circuit breaker, NEMA AB1
- i. Output DC failure alarm relay, for local and remote supervisory annunciation (SCADA)
- j. AC failure alarm relay, for local and remote supervisory annunciation
- k. Surge and transient protection
- l. DC high-low voltage alarm relay
- m. DC output thermal-magnetic circuit breaker
- n. Battery monitoring system shall provide early warning of battery failure and equalization of charge current to each battery cell
- o. Space heaters, as required

### I. EMERGENCY EYE WASH:

- 1. Provide an eye wash unit with twin spray heads, automatic pressure control, push to operate valve, pressure gauge and drainage. Product shall be in conformance with CAL OSHA Industrial Safety Orders and ANSI Z358.1.

### J. DISCONNECT SWITCH AND CIRCUIT BREAKER:

- 1. A two-pole hand-operated disconnect switch shall be provided between the battery and the battery charger
  - a. The rating of switch shall be coordinated with the dc output circuit breaker of battery charger.
  - b. The disconnect switch shall be mounted in a surface mounted NEMA Type 12 enclosure.
  - c. The disconnect switch shall be provided with two normally open (NO) and two normally closed (NC) contacts for monitoring and interlocks.
- 2. Circuit breakers shall be NEMA AB 1 molded case, quick-break, bolt on type, with thermal-magnetic type overload trip, suitable for AC/DC operations.

## DC BATTERY SYSTEM

### K. DC DISTRIBUTION PANELBOARDS:

#### 1. General

- a. The DC distribution panel boards (if required) shall comply with the requirements of UL 67, NEMA 250, NEMA AB 1 and NEMA PB 1.
- b. Each distribution panel board shall contain a main power circuit breaker and branch circuit breaker with spacer blanks and bus provision for future branch circuit breaker installation, as shown on Contract drawing.
- c. The panel board shall be in NEMA Type 1 door-in-door enclosure made of galvanized steel, for surface mounting with multiple knockouts and wiring gutters.
- d. Each distribution panel board shall be provided with a swinging door with full length piano hinge and a flush spring latch.
- e. The open door shall expose the dead front circuit breaker handle and circuit breaker card directory.
- f. Interior component shall be mounted on back plate of reinforce steel for rigid support and accurate alignment.
- g. A moisture resistance circuit identification chart shall be furnished and attached to the inside face of the cover.
- h. Fuses: If DC loads are used from the battery system, such loads shall have a fuse to protect the battery system and load.

#### 2. Electrical Requirements:

- a. The panel boards shall be rated for short circuit of 10,000 amperes interrupting rating minimum and be equipped with two pole molded case circuit breakers and positive and negative bus bars.
- b. Bus bars shall be ASTM B187, 98% conductive copper, with silver plated contact surface.

### L. FINISHES:

1. The battery racks shall be treated with at least two coats of alkaline gray paint.
2. The distribution panel shall be cleaned, primed and finish painted in accordance with the manufacture's standard specifications, suitable for indoor service. The color of exterior finish paint shall be ANSI 61 gray polyester powder finish or equal unless otherwise directed by District.

## DC BATTERY SYSTEM

### M. SOURCE QUALITY CONTROL:

#### 1. GENERAL

- a. **Notification of Test:** The District shall be notified not less than 30 days in advance of dates schedule for test. Test procedure shall be approved by the District prior to the dates of schedule tests.
  - b. **Test Program Plan:** Submit a plan identifying the approach to be used for accomplishing the required shop tests. The projected schedule for the test and test execution, and submittal of the test results shall be included.
  - c. **Test Procedures:** The test procedures shall include as a minimum:
    - 1). Objective and scope
    - 2). Test set up
    - 3). Test equipment to be used
    - 4). Personnel required for the test
    - 5). Estimated duration of the test
    - 6). Pass/fail criteria
    - 7). Samples of data sheets to be used.
    - 8). Test procedures shall be submitted not less than 30 days prior to test.
2. **Test Results:** Test results will be reviewed and accepted by the District representative as submittal or additional tests are required. If additional tests are required because the test results submitted do not comply with the requirements of the specifications, the retesting is to be documented and submitted to the District as a part of the work.
  3. **Test Reports:** Test reports shall document the results obtained and be certified by manufacturer. Report shall include the following:
    - a. Equipment tested including model and serial numbers
    - b. Title of the test
    - c. Objective of the test and pass/fail criteria
    - d. Summary and conclusion
    - e. Location and date of test

## DC BATTERY SYSTEM

- f. Test methods and equipment used for the test
  - g. Results including calculations and other supporting data
  - h. Abbreviations and references
  - i. Signature of the test supervisor and witnesses.
4. **Test Witnessing:** The District reserve the right to witness all tests including factory tests conducted elsewhere by Contactor, its suppliers, or by an independent agency. If District determines not to witness a test or tests, test report shall be submitted to District for review. Test reports shall be signed by all witnessing parties.
  5. **Test Equipment:** Provide annually certified calibrated test equipment, instruments, tools and other required items necessary to perform the test indicated.
- N. **REPLACEMENT MATERIALS:**
1. Replace or repair equipment, parts and materials that are rejected, damaged, lost, or consumed during performance of shop tests. Replacement materials shall be new and warranted.
- O. **FACTORY TESTS:**
1. Factory test shall include design and production tests performed by the Contractor, its supplier, or a testing agency prior to the shipment of the equipment. Unless otherwise indicated, the District may waive the requirements for design tests upon review of test procedures, test results and/or certified documentation of like equipment. Tests results on like equipment or materials shall be submitted for design tests which are to be waived.
  2. Factory test shall be performed to include the following tests for the DC control power supply.
    - a. Temperature rise test
    - b. Power loading at 100% capacity for 24 hours at 32°C and 90% humidity

### **PART 3-EXECUTION:**

#### **3.01 INSTALLERS:**

The Contractor shall install the battery and battery charger including the associated devices in the train control battery rooms or other BART facilities with the manufacturer's recommendations and as shown in the Contract Drawings

## DC BATTERY SYSTEM

### 3.02 EXAMINATION:

The Contactor shall examine areas and conditions for compliance with requirement of DC Control Power system

### 3.03 INSTALLATION:

- A. The installation of dc distribution panelboards shall comply with the requirements of NEMA PB 1.1
- B. Battery and Battery Charger:
  - 1. The racks shall be bolted to the floor and shall comply with seismic requirements of the current California Building Code (CBC).
  - 2. The battery and rack assembly shall be arranged to provide easy access to each battery cell or module for maintenance and replacement.
  - 3. The cables or the bus bars between battery cell or module shall be securely connected.
  - 4. The battery charger shall be installed as indicated on the Contract Drawings.

### 3.04 TRICKLE BATTERY CHARGER:

Trickle Charger shall be provided to charge the battery when main charger is not available. When battery string integrated with UPS system then trickle charger shall be disconnected.

- 1. Trickle battery charger shall be provided for each battery string.
- 2. The trickle battery charger shall stop the charging automatically after the batteries are fully charged.
- 3. The trickle charger shall be 120vac single phase input. The output shall be consistent with the battery string voltage.

### 3.05 FIELD QUALITY CONTROL:

- A. Power distribution test shall verify that the energy at all level is available and is properly distributed to the equipment requiring power in the train control rooms and other BART facilities. The test shall include verification:
  - 1. No grounds, short circuits, open circuits, or misplaced wiring exists in the power distribution system.
  - 2. Standby, reserve and battery power circuitry are complete and operate properly.
  - 3. Output AC power supplies, provide the correct voltage levels and phasing where required, record voltages.

## DC BATTERY SYSTEM

4. Output DC power supplies, provide the correct voltage levels and correct polarity, record voltage and loads.
5. Adjustable transformer or voltage regulators are adjusted correctly.
6. Ground fault detectors are operating correctly.

### **3.06 CLEANING:**

On completion of installation, the Contractor shall inspect the battery and battery charger and ancillary equipment. The contractor shall remove paint splatters and other spots. The Contractor shall remove excess materials, vacuum dirt and debris. The Contractor shall repair exposed surfaces to match original finish.

### **3.07 DEMONSTRATION:**

A factory authorized service representative shall demonstrate operation of equipment for the District's maintenance personnel to adjust, operate and maintain DC power system controls, protective devices, instrumentation and accessories.

**END OF SECTION 26 33 01**