

SECTION 26 05 26

GROUNDING AND BONDING FOR ELECTRICAL SYSTEMS

PART 1 - GENERAL

1.01 SECTION INCLUDES

- A. Grounding and bonding equipment.
- B. Grounding rods.
- C. Bare conductors.
- D. Bus bar.
- E. Single conductor insulated wire.
- F. Terminal lugs.
- G. Jumpers.

1.02 RELATED SECTIONS

- A. Cathodic protection is specified in Section 26 42 00 - Cathodic Protection.

1.03 MEASUREMENT AND PAYMENT

- A. General: Grounding and bonding for electrical systems, as specified herein, will not be measured separately for payment but will be paid for as part of the Contract lump sum price for Electrical Work as indicated in the Bid Schedule of the Bid Form.

1.04 REFERENCES

- A. American Society for Testing and Materials (ASTM):
 - 1. ASTM B3 Specification for Soft or Annealed Copper Wire
 - 2. ASTM B187 Specification for Copper Bar, Bus Bar, Rod and Shapes
- B. Institute of Electrical and Electronics Engineers (IEEE):
 - 1. IEEE 837 Qualifying Permanent Connections Used in Substation Grounding
- C. Underwriters Laboratories Inc. (UL):
 - 1. UL 467 Grounding and Bonding Equipment

1.05 REGULATORY REQUIREMENTS

- A. Refer to Section 20 70 26 - Common Materials and Methods for Electrical Systems, for requirements.

1.06 SUBMITTALS

- A. General: Refer to Section 01 33 00 - Submittal Procedures, and Section 01 33 23 - Shop Drawings, Product Data, and Samples, for submittal requirements and procedures.
- B. Shop Drawings: Submit Shop Drawings showing locations of ground rods, grounding connections, locations of embedded and buried grounding conductors, and locations of stubouts and pigtails for future connections to the grounding system by others. Drawings shall also indicate locations of test points to measure grounding resistance.
- C. Product Data: Submit manufacturers' product data of manufactured materials.
- D. Test Reports: Submit copies of certified test reports of grounding resistance tests, including method of measurement.

1.07 DELIVERY, STORAGE AND HANDLING

- A. Provide marking on wire and cable in accordance with applicable standards. Each item shall be UL-labeled.
- B. Ship each item of equipment and materials securely wrapped, packaged, and labeled for safe handling in shipment and to avoid damage.
- C. Store equipment and materials in secure and dry storage facility.

PART 2 - PRODUCTS

2.01 EQUIPMENT AND MATERIALS

- A. Grounding and Bonding Equipment: Conform to UL 467 and the additional requirements specified herein.
- B. Ground Rods: Medium carbon steel core, copper-clad by the molten weld casting process, size of 1 inch in diameter by 10 feet long or as indicated, UL listed.
- C. Bare Conductors: ASTM B3, Class B stranded, annealed copper conductor, unless otherwise indicated, size as indicated.
- D. Bus Bar: ASTM B187, 98 percent conductivity copper, size as indicated.
- E. Single Conductor Insulated Wire: Refer to Section 26 05 24 - Low and Medium Voltage Wires and Cables. Use insulated ground wire for grounding communication and train control systems.
- F. Terminal Lugs: Refer to Section 20 70 26 - Common Materials and Methods for Electrical Systems

- G. Jumpers: Tin-plated copper, braided, flexible jumper.

PART 3 - EXECUTION

3.01 INSTALLATION OF GROUNDING SYSTEM

A. Ground Connections:

1. Provide exothermically welded or compression-type terminal lugs for buried or embedded connections using materials qualified in accordance with IEEE 837. Bolted connections shall not be buried or embedded. For compression-type connectors, the tool for crimping shall emboss the die index number into the connector as the crimp is completed. Each compression-type connector shall have an inspection port for use in checking proper conductor insertion.
2. All connections shall be made in accordance with the manufacturer's requirements. All connections shall be cleaned and coated with a bitumastic epoxy before backfilling.
3. Above ground connections shall be made using materials qualified in accordance with IEEE 837. All connections shall be made in accordance with the California Electrical Code and the manufacturer's recommendations.
4. Provide continuous ground conductor or splice using connections qualified in accordance with IEEE 837. All splice connections shall be made in accordance with the manufacturer's requirements.
5. Connect the bus bar to station ground system as indicated. Provide waterstops on ground cable risers, where the risers enter the structure.

B. Ground Rods:

1. Bury ground rods vertically with rod top a minimum of two feet below grade as indicated. Use ground rod as indicated for main grounding system. If extensive rock formation is encountered, relocate ground rods to a new location as approved by the Engineer.
2. Interconnect ground rods with minimum 250 kcmil stranded bare copper cable or as indicated.
3. Ground the frames of motors larger than 25 hp by a ground conductor carried in the power conduit. Provide a ground conductor sized in accordance with the California Electrical Code.
4. Ground the non-current-carrying metal enclosures of transformers with a conductor sized as indicated or as required by the California Electrical Code.

- C. Grounding Wires: All grounding wires shall be as indicated and sized to provide adequate conduction path for all possible faults and electrical interference currents.

- D. Grounding Requirements: Provide separate systems and equipment grounding as indicated. Ground metallic conduits, raceways, under-floor ducts, cable trays, boxes, cabinets, exposed expansion joints, lighting fixtures, and receptacles in accordance with the California Electrical Code.

3.02 FIELD QUALITY CONTROL

- A. Ground Resistance:
1. Test the grounding system by the fall-of-potential method under the observation of the Engineer. Unless otherwise indicated, demonstrate that total ground resistance does not exceed 5Ω .
 2. The ground resistance shall not exceed 0.5Ω as measured from equipment racks to ground plate in train control rooms and from wayside devices to system ground bus or ground rod connection.
 3. To meet these resistance requirements, if necessary, bury additional ground rods or use electrolytic grounding electrodes, or soldier piles as grounding conductors.
- B. Ground System Continuity: Test equipment enclosures, conduit, raceways, exposed expansion joints, lighting fixtures, receptacles, light standards, and metal fencing for continuity to the ground system.

END OF SECTION 26 05 26